



ST. CHARLES  
SINCE 1834

## AGENDA ITEM EXECUTIVE SUMMARY

Title: Electric Reliability Report – Information Only

Presenter: Tom Bruhl

*Please check appropriate box:*

|                                     |                        |   |                              |
|-------------------------------------|------------------------|---|------------------------------|
| <input checked="" type="checkbox"/> | Government Operations  | X | Government Services 03.24.14 |
| <input type="checkbox"/>            | Planning & Development |   | City Council                 |
| <input type="checkbox"/>            | Public Hearing         |   |                              |

|                 |    |           |     |  |    |  |
|-----------------|----|-----------|-----|--|----|--|
| Estimated Cost: | \$ | Budgeted: | YES |  | NO |  |
|-----------------|----|-----------|-----|--|----|--|

If NO, please explain how item will be funded:

### Executive Summary:

For information only.

### Attachments: *(please list)*

February 2014 Outage Report.

### Recommendation / Suggested Action *(briefly explain):*

For information only.

*For office use only:*

*Agenda Item Number: 3.a*

| General Information |           |     |         |                    | Cause                                   |   | Time & Duration |                  |                 |      | Customers |          |
|---------------------|-----------|-----|---------|--------------------|---|---|-----------------|------------------|-----------------|------|-----------|----------|
| #                   | Date      | S/U | Circuit | Address/Location   | Description                             | # | Ints            | T off            | T on            | Mins | # Out     | Cust Min |
| 1                   | 2/5/2014  | U   | 331     | 818 Viewpointe Dr. | Transformer; damaged by snow contractor | 8 | 1               | 2/5/14 9:24 AM   | 2/5/14 10:10 AM | 46   | 7         | 322      |
| 2                   | 2/5/2014  | U   | 331     | 818 Viewpointe Dr. | Transformer; damaged by snow contractor | 8 |                 | 2/5/14 9:24 AM   | 2/5/14 11:15 PM | 831  | 4         | 3324     |
| 3                   | 2/19/2014 | U   | 332     | 217 S. 3rd Ave.    | Overhead; connector failure             | 1 | 1               | 2/19/14 12:00 PM | 2/19/14 1:10 PM | 70   | 1         | 70       |

S/U - Scheduled or Unscheduled  
 Ints - # of Interruptions  
 Long - >1 min; Short - <1 min  
 Cause # - see table on page 3