

**City of St. Charles**

**34.5 kV Padmounted  
Switchgear Specification  
Addendums**

City of St. Charles  
Two East Main Street  
St. Charles, IL 60174-1984

May, 2016

## City of St. Charles

### 34.5kV Outdoor Padmounted Switchgear Specification Addendums

#### **Addendum 1:**

The words that are crossed out are to be removed From Part 2 Section E:

~~The Vendor shall provide or contract for the necessary equipment and manpower to unload the gear at the site.~~ Note – Vendor responsible for compliance with the Illinois Prevailing Wage Act.

The Vendor is responsible to deliver the unit to the City garage. City crews will install the switchgear on the pad at the substation.

#### **Addendum 2:**

The wording is to be added to Part 3 Section A:

The vacuum interrupter in way 3 that is feeding the transformer is to be supplied with a motor operator so that opening and closing of way 3 can be done with the SEL787 relay as well as manually.