



A. CURB BOX:

1. MUELLER H-10300 WITH 1-1/4" I.D. UPPER SECTION AND 2" MINEAPOLIS TAPPED BASE.
2. A.Y. MCDONALD 5615 1-1/4"

B. CURB STOP:

- MUELLER B-25155-N (1", 1 1/2", 2")
 FORD B-44-444-Q-NL 1"
 B-44-666-Q-NL 1 1/2"
 B-44-777-Q-NL 2"
 A.Y. MCDONALD 76104-Q 1", 1 1/2", 2"
 Q SERIES BRASS

C. CORPORATION STOP:

- MUELLER B-25008-N (1", 1-1/2", 2")
 FORD FB1000 -4-Q-NL 1"
 FB 1000-6-Q-NL 1-1/2"
 FB 1000-7-Q-NL 2"
 A.Y. MCDONALD 74701-BQ 1", 1-1/2", 2"
 Q SERIES BRASS, WITH 90 SWIVEL ELBOW

NOTES:

1. PIPE SIZE CAN VARY, BUT 1" MINIMUM. OTHER APPURTENANCES SHALL REFLECT SAME.
2. COPPER PIPE SHALL BE ONE PIECE BETWEEN TAP AND CURB BOX.
3. PLACE BETWEEN SIDEWALK AND PROPERTY LINE. KEEP BOXES OUT OF SIDEWALKS AND DRIVEWAY.
4. MINIMUM OF 3' BETWEEN TAPS AND 3' TO NEAREST JOINT.
5. 1" SERVICE MAY BE DIRECTLY TAPPED INTO 6" OR LARGER MAIN. LARGER SERVICES REQUIRE A SMITH-BLAIR 372 OR APPROVED EQUAL STAINLESS STEEL TAP THROUGH SLEEVE.

NOT TO SCALE

**COPPER
 WATER SERVICE
 CONNECTION
 DETAILS**

DATE: 11-12-13