



NOTE:

1. INLET TO BE CONSTRUCTED OF PRECAST REINFORCED CONCRETE.
2. INLET MUST CONFORM TO ASTM C-478.
3. NON-PRECAST OPENINGS SHALL BE CORED AND RUBBER BOOTED.
4. MAXIMUM DEPTH FROM INVERT OF OUTLET PIPE TO TOP OF FRAME SHALL NOT EXCEED 42 INCHES. IF DESIGN OR CONSTRUCTION REQUIRES DEPTH BEYOND 42 INCHES, STRUCTURE SHALL BE REVISED TO A 48 INCH DIAMETER TY A MANHOLE.

NOT TO SCALE

TYPE A INLET
DETAIL

DATE: 3-31-09