


HYDRANT SPECIFICATIONS:

1. WATEROUS PACER MODEL WB-67-250 OR APPROVED EQUAL.
2. MECHANICAL JOINT SHOE WITH 6" RESILIENT WEDGE AUXILIARY VALVE.
3. 5-1/4" VALVE AUXILIARY BOX.
4. 5'-6" MIN. COVER OVER HYDRANT LATERAL.
5. VALVE BOX SHALL HAVE AN INTERNAL VALVE BOX STABILIZER INSTALLED.



CITY OF ST. CHARLES
 ILLINOIS • SINCE 1834
Pride of the Fox

HYDRANT INSTALLATION

DATE: 5-12-2021

NOT TO SCALE

REVISED:

DRAWING NO. B-04