


NOTES:

1. INLET TO BE CONSTRUCTED OF PRECAST REINFORCED CONCRETE.
2. INLET MUST CONFORM TO ASTM C-478.
3. NON-PRECAST OPENINGS SHALL BE CORED.
4. MAXIMUM DEPTH FROM INVERT OF OUTLET PIPE TO TOP OF FRAME SHALL NOT EXCEED 42 INCHES. IF DESIGN OR CONSTRUCTION REQUIRES DEPTH BEYOND 42 INCHES, STRUCTURE SHALL BE REVISED TO A 48 INCH DIAMETER TYPE A MANHOLE.



CITY OF ST. CHARLES
 ILLINOIS • SINCE 1834
Pride of the Fox

TYPE A INLET

DATE: 9-10-2021

NOT TO SCALE

REVISED:

DRAWING NO. C-05