

A. CURB BOX:

MUELLER H-10300 WITH 1-1/4" I.D. UPPER SECTION AND 2" MINNEAPOLIS TAPPED BASE.
 A.Y. McDONALD 5615 1-1/4"

B. CURB STOP:


MUELLER B-25155-N (1", 1 1/2", 2")
 FORD B-44-444-Q-NL 1"
 B-44-666-Q-NL 1 1/2"
 B-44-777-Q-NL 2"
 A.Y. McDONALD 76104-Q 1", 1 1/2", 2"
 Q SERIES BRASS

C. CORPORATION STOP:

MUELLER B-25008-N (1", 1-1/2", 2")
 FORD FB 1000-4-Q-NL 1"
 FB 1000-6-Q-NL 1-1/2"
 FB 1000-7-Q-NL 2"
 A.Y. McDONALD 74701-BQ 1", 1-1/2", 2"
 Q SERIES BRASS, WITH 90 SWIVEL ELBOW

NOTES:

1. PIPE SIZE CAN VARY, BUT 1" MINIMUM. OTHER APPURTENANCES SHALL REFLECT SAME.
2. COPPER PIPE SHALL BE ONE PIECE BETWEEN TAP AND CURB BOX.
3. PLACE CURB BOX BETWEEN SIDEWALK AND PROPERTY LINE, AVOIDING SIDEWALKS & DRIVEWAY.
4. MINIMUM OF 3' BETWEEN TAPS AND 3' TO NEAREST WATERMAIN JOINT.
5. 1" SERVICE MAY BE DIRECTLY TAPPED INTO 6" OR LARGER MAIN. LARGER SERVICES REQUIRE A FULL CIRCLE SADDLE MADE OF GRADE 304 STAINLESS STEEL WITH NYLON WASHERS AND NITRILE GASKETS. SADDLES ON CAST IRON PIPE SHALL HAVE A MIN. WIDTH OF 6".
6. FOR HDPE PIPE CONTACT THE PUBLIC WORKS DEPARTMENT.



CITY OF ST. CHARLES
 ILLINOIS • SINCE 1834
Pride of the Fox

COPPER WATER SERVICE CONNECTION

DATE: 9-10-2021

NOT TO SCALE

REVISED:

DRAWING NO. B-06