

	AGENDA ITEM EXECUTIVE SUMMARY						
	Title:	Electric Reliability Report – Information Only					
	Presenter:	Tom Bruhl					
<i>Please check appropriate box:</i>							
	Government Operations	X	Government Services 10.28.13				
	Planning & Development		City Council				
	Public Hearing						
Estimated Cost:	\$	Budgeted:	YES		NO		
If NO, please explain how item will be funded:							
Executive Summary:							
For information only.							
Attachments: <i>(please list)</i>							
September 2013 Outage Report.							
Recommendation / Suggested Action <i>(briefly explain):</i>							
For information only.							
<i>For office use only:</i>		<i>Agenda Item Number: 3.a</i>					

General Information				Cause		Time & Duration				Customers	
#	Date	S/U	Circuit, Address/Location	Description	#	Ints	T off	T on	Mins	# Out	Cust Min
1	9/1/2013	U	713; NE side of town	Underground failure, primary cable failure.	2	1	9/1/13 7:14 AM	9/1/13 7:14 AM	0	749	0
2	9/1/2013	U	713; 4000 Blk Royal Fox Dr.	Underground failure, primary cable failure.	2	1	9/1/13 7:14 AM	9/1/13 8:10 AM	56	13	728
3	9/1/2013	U	713; Royal Troon Ct.	Underground failure, primary cable failure.	2		9/1/13 7:14 AM	9/1/2013 8:25	71	13	923
4	9/5/2013	U	314; Allen Ln. E. of Rt. 25	Skyline, dropped branch on service.	7	1	9/5/13 11:30 AM	9/5/13 12:00 PM	30	11	330
5	9/5/2013	S	713; Dunham Rd. lift station by H.S.	Scheduled, shut off power for electrician's repairs.	10	1	9/5/13 10:10 AM	9/5/13 11:00 AM	50	1	50
6	9/10/2013	U	532; Swift Eckrich	Underground failure, metering failure	2	1	9/10/13 5:55 PM	9/10/13 8:25 PM	150	2	300
7	9/10/2013	S	811; 3091 St. Michel Ln.	Scheduled, to install pedestal.	10	1	9/10/13 1:08 PM	9/10/13 1:42 PM	34	1	34
8	9/20/2013	U	311; 611 S. 10th Ave.	Squirrel, blew transformer fuse.	2	1	9/20/13 7:25 AM	9/20/13 8:00 AM	35	8	280
9	9/20/2013	U	314; 808 & 820 N. 5th Ave.	Equipment, primary cable fault	2	1	9/20/13 2:30 PM	9/20/13 7:30 PM	300	2	600
10	9/25/2013	U	316; 1300-1600 Block E. Main	Others, landscaper knocked transformer off	10	1	9/25/13 2:22 PM	9/25/13 3:30 PM	68	26	1768

S/U - Scheduled or Unscheduled

Ints - # of Interruptions

Long - >1 min; Short - <1 min

Cause # - see table on page 3