

	AGENDA ITEM EXECUTIVE SUMMARY												
	Title:		Electric Reliability Report – Information Only										
	Presenter:		Tom Bruhl										
<i>Please check appropriate box:</i>													
	Government Operations		X	Government Services 02.03.14									
	Planning & Development			City Council									
	Public Hearing												
<table border="1" style="width: 100%;"> <tr> <td>Estimated Cost:</td> <td>\$</td> <td>Budgeted:</td> <td>YES</td> <td></td> <td>NO</td> <td></td> </tr> </table>							Estimated Cost:	\$	Budgeted:	YES		NO	
Estimated Cost:	\$	Budgeted:	YES		NO								
If NO, please explain how item will be funded:													
Executive Summary:													
For information only.													
Attachments: <i>(please list)</i>													
November & December 2013 Outage Reports.													
Recommendation / Suggested Action <i>(briefly explain):</i>													
For information only.													
<i>For office use only:</i>		<i>Agenda Item Number: 3.a</i>											

General Information				Cause		Time & Duration				Customers	
#	Date	S/U	Circuit, Address/Location	Description	#	Ints	T off	T on	Mins	# Out	Cust Min
1	11/2/2013	U	622, Prairie St., Randall Rd., Oak St.	Underground switch failure. Momentary.	2	1	11/2/13 10:06 AM	11/2/13 10:06 AM	0	480	0
2	11/3/2013	S	622, 600 S. Randall Rd.	SCMEU, switched out switchgear & transformer.	2	1	11/3/13 7:30 AM	11/3/13 11:00 AM	210	3	630
3	11/4/2013	U	334, SE Quadrant of City, 1/2 of Q Center	Overhead arrestor blown. Momentary.	1	1	11/4/13 7:49 PM	11/4/13 7:49 PM	0	833	0
4	11/15/2013	U	216, 2210 Dean St.	Human error, Utility personnel.	7	1	11/15/13 1:15 PM	11/15/13 1:15 PM	0	6	0
5	11/17/2013	U	214, Howard/Oak/Evergreen/S 15th St.	Weather, large branch fell during heavy wind.	3	1	11/17/13 11:36 AM	11/17/13 1:06 PM	90	90	8100
6	11/17/2013	U	214, Howard/Oak/Evergreen/S 15th St.	Weather, large branch fell during heavy wind.		1	11/17/13 11:36 AM	11/17/13 2:36 PM	180	29	5220
7	11/17/2013	U	IYC Rt. 38	Others, internal problem. Customer fault inside.	8	1	11/17/13 3:14 PM	11/17/13 8:00 PM	286	1	286
8	11/23/2013	S	216, Randallwood	SCMEU, transformer changed out.	8	1	11/23/13 8:00 AM	11/23/13 11:10 AM	190	7	1330
9	11/9/2013	U	13156; SE Quad. Of town	ComEd line loss, arrester failure.	0	1	11/9/13 10:04 AM	11/9/13 10:04 AM	0	532	0
10	11/27/2013	U	214, 1525, 1545 & 1615 W. Main	Overhead, pole fire.	1	1	11/27/13 9:30 PM	11/27/13 10:00 PM	30	3	90

S/U - Scheduled or Unscheduled

Ints - # of Interruptions

Long - >1 min; Short - <1 min

Cause # - see table on page 3

General Information				Cause		Time & Duration				Customers	
#	Date	S/U	Circuit, Address/Location	Description	#	Ints	T off	T on	Mins	# Out	Cust Min
1	12/10/2013	U	624, 1015 S. 3rd St.	Tree limb, rerouted wire.	5	1	12/10/13 2:00 PM	12/10/13 2:30 PM	30	1	30
2	12/13/2013	U	224, 218 Millington Way	Underground, metering failure.	2	1	12/13/13 5:42 AM	12/13/13 6:30 AM	48	1	48
3	12/15/2013	U	624, 726 Mosedale St.	Overhead, metering failure.	1	1	12/15/13 3:43 PM	12/15/13 4:35 PM	52	1	52
4	12/18/2013	U	734, 652 Kirk Rd.	Others, vehicle accident.	8	1	12/18/13 6:46 PM	12/18/13 9:15 PM	149	1	149
5	12/28/2013	U	311, 910 Madison Ave.	Overhead, connector failure.	1	1	12/28/13 7:00 PM	12/28/13 8:30 PM	90	1	90

S/U - Scheduled or Unscheduled

Ints - # of Interruptions

Long - >1 min; Short - <1 min

Cause # - see table on page 3