



ST. CHARLES
SINCE 1834

AGENDA ITEM EXECUTIVE SUMMARY

Title: Electric Reliability Report – Information Only

Presenter: Tom Bruhl

Please check appropriate box:

<input checked="" type="checkbox"/>	Government Operations	X	Government Services 04.28.14
<input type="checkbox"/>	Planning & Development		City Council
<input type="checkbox"/>	Public Hearing		

Estimated Cost:	\$	Budgeted:	YES		NO	
-----------------	----	-----------	-----	--	----	--

If NO, please explain how item will be funded:

Executive Summary:

For information only.

Attachments: *(please list)*

March 2014 Outage Report.

Recommendation / Suggested Action *(briefly explain):*

For information only.

For office use only:

Agenda Item Number: 3.a

General Information					Cause		Time & Duration				Cust
#	Date	S/U	Circuit	Address/Location	Description	#	Ints	T off	T on	Mins	# Out
1	3/5/2014	U	L13150	Central area of City	Mylar balloon in the line by Smitty's	0	1	3/5/14 2:10 PM	3/5/14 2:10 PM	0	3,063
2	3/5/2014	U	214	SW quadrant, Main to Randall to Prairie to 7	Car accident into pole at 15th and Oak	10	1	3/5/14 3:52 PM	3/5/14 3:52 PM	0	1,020
3	3/5/2014	U	214	Oak to Randall to Prairie to 15th St	Car accident into pole at 15th and Oak. Restored	10	1	3/5/14 3:52 PM	3/5/14 5:08 PM	76	338
4	3/5/2014	U	214	Main to Randall to Prairie to 7th	Car accident into pole at 15th and Oak - Isolated a	10		3/5/14 4:22 PM	3/5/14 4:49 PM	27	126
5	3/12/2014	U	331/332	813 S. 2nd St. - Indiana Ave.	Breaker operation from tree	5	1	3/12/14 3:05 PM	3/12/14 3:05 PM	0	1,348
6	3/12/2014	U	331	Viewpointe to Willowgate	Breaker operation from tree	5	1	3/12/14 3:05 PM	3/12/14 4:07 PM	62	217
7	3/12/2014	U	331	S. 2nd St. to Horne St.	3 phase down from tree on wires	5	1	3/12/14 3:32 PM	3/12/14 4:07 PM	35	470
8	3/22/2014	U	312	500 Block S. 4th Ave.	Split bolt from transformer lead to secondary	1	1	3/22/14 9:45 PM	3/22/14 10:00 PM	15	8
9	3/23/2014	U	311/312	SE and SW quadrants of City	Suspected arrester failure - did not find	9	1	3/23/14 6:32 PM	3/23/14 6:32 PM	0	1,427
10	3/25/2014	U	624	910 S. 4th St.	Underground service fault	2	1	3/25/14 8:30 PM	3/25/14 10:00 PM	90	1
11	3/30/2014	U	331	2nd St, from Indiana & Viewpointe	Squirrel, underground equipment failure.	4	1	3/30/14 9:05 AM	3/30/14 10:04 AM	59	37

S/U - Scheduled or Unscheduled
 Ints - # of Interruptions
 Long - >1 min; Short - <1 min
 Cause # - see table on page 3